

Appliance / Location

Press: Working/Operating

Ref.

Log ID 1
Date 14:16 02-Nov-2024

Fuel Light oil

O2 (%).....4.1
CO (ppm).....14
CO2 (%).....12.5
Ratio.....0.0001
Pressure (mBar)....-0.11
XS air (%).....24.1
Temp dewpt (C).....51
Eff netHE (%).....103.0
Temp. flue (C).....33
Temp. inlet (C).....15
Temp. net (C).....18

Vortex Module 25-40
1700424601 Date Code: 20-9-24
R087.2 BX VIS-32
ITD10029 Burner Code: DZ00
Postcode
Mobile
nt ☒ Open Vented ☒ or Sealed System
es ☒ No ☐ Flue Type: CASVE
Boiler Location: CASVE
What cleanser was used?
Which inhibitor was used?
d? Yes
2 pipe ☒ De-aerator ☒
fitted to oil pump? Yes
um been fitted? Yes